

HOLIDAY ENTERPRISES, INC.
dba Holiday Water Company
PO BOX 309
TOMBSTONE, AZ 85638
520-508-9037 Office
520-255-9143 Emergency
holidaywtr@gmail.com



ORIGINAL

Docket #W-01896A-13-0238
Docket #W-01896A-13-0239
Decision No. 74261


March 10, 2014

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Arizona Corporation Commission

DOCKETED

MAR 11 2014



Attached is an application by Holiday Water Company for approval of a:

Meter Repair and/or Replacement Tariff – BMP 4.2

The purpose of this tariff is to establish guidelines for a Meter Repair and/or Replacement Program & to comply with Decision No. 74261 Order page 27 Line 1 through 4.

Thank you,

Carol E Cowan
Manager

RECEIVED
2014 MAR 11 A 10:51
AZCP COMMISSION
DOCKET CONTROL

Utility: **Holiday Water Company**

Phone: **520-508-9037**

Decision: **74261**

Page: **1 of 1**

Docket No: **W-01896A-13-0238 & 13-0239**

Effective Date: _____

Meter Repair and/or Replacement Tariff – BMP 4.2

PURPOSE

A program for the Company to systematically assess all in-service water meters (including Company production meters) in its water service area to identify under-registering meters for repair or replacement (Modified Non-Per Capita Conservation Program Best Management Practice Category 4: Physical System Evaluation and Improvement 4.2 Meter Repair and/or Replacement Program).

REQUIREMENTS

The requirements of this tariff are governed by Rules of the Arizona Corporation Commission and were adapted from the Arizona Department of Water Resources' Required Public Education Program and Best Management Practices in the Modified Non-Per Capita Conservation Program.

1. On a systematic basis, the Company will inspect 100 percent of its 1-inch and smaller in-service water meters at least once every ten years for one of the following reasons (whichever occurs first):
 - a. A meter reading complaint is filed with the Company by a customer or Arizona Corporation Commission Staff,
 - b. A meter has registered 1,000,000 gallons of usage,
 - c. A meter has been in service for ten years.
2. Meters larger than 1-inch shall be inspected for one of the following reasons:
 - a. A meter reading complaint is filed with the Company by a customer or Arizona Corporation Commission Staff,
 - b. A meter has been in service for five years.
3. The inspection will be accomplished by having the meter pulled and having a Company Technician physically inspect each meter and its fittings for leaks, registers which may have become loose or are not properly attached to the meter and could be under-registering or other broken parts which need repair. In addition, meters shall be randomly selected for flow testing to identify potentially under-registering meters.
4. The Company shall also replace or reprogram any water meters that do not register in gallons. Upon the effective date of this tariff, the Company shall install all replacement meters with new:
 - a. 1-inch and smaller meters that register in 1 gallon increments,
 - b. 1-1/2-inch through 4-inch meters that register in 10 gallon increments, and
 - c. 6-inch and larger meters that register in 100 gallon increments.
5. The Company shall keep records of all inspected and replacement meters and make this information available to the Commission upon request.